



**North Collier Fire Control and Rescue District
Authority Having Jurisdiction (AHJ) Guidelines for Successful Review or Inspection**

Article Number	FDC 17-01
Effective Date	November 3, 2017
Subject	Maximum Distance Between Fire Department Connections and Fire Hydrants
Objective	To Clarify a Standard on the Maximum Distance Allowed Between a Fire Department Connection and a Fire Hydrant

BACKGROUND

This requirement is based on current firefighting operational procedures used by North Collier Fire Control and Rescue District.

POLICY/PROCEDURE

The North Collier Fire Control and Rescue District requires that all new Fire Department Connections (FDCs) are located within 50 feet of a fire hydrant and within 50 feet of a fire department vehicle access road, whether for a fire sprinkler or standpipe systems.

Exception: This does not apply to buildings classified as high-rise buildings.

CODE REFERENCES

NFPA 24-7.2.1, NFPA 14-5.1.1, 5.1.2