



**North Collier Fire Control and Rescue District
Authority Having Jurisdiction (AHJ) Guidelines for Successful Review or Inspection**

Article Number	FSPK 20-08
Effective Date	March 3, 2020
Subject	Fire Sprinkler Floor and Attic Plans
Objective	Clarify Requirements for Separate Attic and Floor Fire Sprinkler Plans

BACKGROUND

Fire sprinkler system submittals are required to provide plans for each floor. Layout, ceiling grid (if applicable), pipe sizes, pipe lengths, notes, truss layout, etc. and other required features for both areas add to the complexity for review and inspection.

POLICY/PROCEDURE

Therefore, attic fire sprinkler plans, even when on the same piping serving the floor below, shall be indicated on a separate plan from the floor plan. It is acceptable to have a combined plan only when accompanied by plans that show both levels separately.

CODE REFERENCE

NFPA 13-23.1.3