



**North Collier Fire Control and Rescue District
Authority Having Jurisdiction (AHJ) Guidelines for Successful Review or Inspection**

Article Number	FSPK 21-01
Effective Date	January 26, 2021
Subject	Electric Monitoring of Fire Sprinkler Control Valves
Objective	Clarify What Valves are Required to be Electrically Monitored

POLICY/PROCEDURE

All aboveground valves or PIVs that control water exclusively supplying a fire sprinkler system shall be electrically monitored. Other valves in the supply serving other infrastructure such as a master meter which served fire hydrants or potable water to a site in addition to the fire sprinkler system are not required to be electrically monitored, however, they shall be chained and locked in the open position.

CODE REFERENCE

FBC 903.4 and 903.4.1 Exception 2, FFPC 1:13.1.8, FFPC 101:9.7.2.1, NFPA 72 23.8.5.6.1 and A.23.8.5.6.1 (1) through (7), NFPA 13 8.16.1.1.2.1 (1), and Section 13.3.1.7.1.1 of respective Resolutions 08-018, 08-07-04, 2008-06, and respective Ordinances Section 58-27(E)x) Subsection 13.3.1.7.1.1 and Section 58-27(E)xxi) Subsection 13.7.1.4.11.1.2 (December 2020)