



**North Collier Fire Control and Rescue District  
Authority Having Jurisdiction (AHJ) Guidelines for Successful Review or Inspection**

<b>Article Number</b>	ACC 15-03
<b>Effective Date</b>	January 1, 2015
<b>Subject</b>	Emergency Vehicle Access Roads - Clearances
<b>Objective</b>	Clarify and Establish Minimum Unobstructed Clearance of Emergency Vehicle Access Roads

**BACKGROUND**

FFPC NFPA 1-Chapter 18 allows the AHJ to increase vertical clearances to accommodate fire apparatus. The following policy has been adopted due to the height of newer fire apparatus and the overhead obstructions they may encounter with older structures (guard houses, overhangs, etc.)

**POLICY/PROCEDURE**

Fire department access roads shall have an unobstructed vertical clearance of not less than 14 ft. Vegetation shall be trimmed to comply with this requirement.

**CODE REFERENCES**

FFPC NFPA 1-18.2.3.4.1.2.2