



**North Collier Fire Control and Rescue District  
Authority Having Jurisdiction (AHJ) Guidelines for Successful Review or Inspection**

<b>Article Number</b>	ACC 15-04
<b>Effective Date</b>	January 1, 2015
<b>Subject</b>	Fire Lane Turning Radius
<b>Objective</b>	Clarify and Establish Minimum Turning Radius for Emergency Vehicle Access Roads

**BACKGROUND**

FFPC (NFPA 1- Chapter 18) requires that the turning radius of emergency vehicle access roads shall be approved by the AHJ. The following clarifies the required turning radius for emergency vehicle access roads.

**POLICY/PROCEDURE**

The turning radius for emergency vehicle access roads, not exceeding a 90 degree turn, where serving buildings shall be 25 ft. inside and 50 ft. outside.

The turning radius for emergency vehicle access roads serving parking lots only shall be 25 ft. inside and 45 ft. outside.

Where turns exceed 90 degrees, the policy and procedure for dead-end turnarounds shall apply (ACC 15-01).

**CODE REFERENCES**

FFPC (NFPA 1- Chapter 18)