



**North Collier Fire Control and Rescue District  
Authority Having Jurisdiction (AHJ) Guidelines for Successful Review or Inspection**

<b>Article Number</b>	FDC 17-01
<b>Effective Date</b>	November 3, 2017
<b>Subject</b>	Maximum Distance Between Fire Department Connections and Fire Hydrants
<b>Objective</b>	To Clarify a Standard on the Maximum Distance Allowed Between a Fire Department Connection and a Fire Hydrant

**BACKGROUND**

This requirement is based on current firefighting operational procedures used by North Collier Fire Control and Rescue District.

**POLICY/PROCEDURE**

The North Collier Fire Control and Rescue District requires that all new Fire Department Connections (FDCs) are located within 50 feet of a fire hydrant and within 50 feet of a fire department vehicle access road, whether for a fire sprinkler or standpipe systems.

Exception: This does not apply to buildings classified as high-rise buildings.

**CODE REFERENCES**

NFPA 24-7.2.1, NFPA 14-5.1.1, 5.1.2